


CERTIFICATE

Certificate holder	FISCHER Mess- und Regeltechnik GmbH Bielefelder Str. 37a 32107 Bad Salzuflen GERMANY
Product	Flow switches for heat transfer installations
Type, Model	NK10...
Testing basis	DIN 4754-3:2015-03 Zertifizierungsprogramm Strömungs- und Füllstandsicherungen (2016-01)
Mark of conformity	
Registration No.	10F001
Valid until	2025-10-31
Right of use	This certificate entitles the holder to use the mark of conformity shown above in conjunction with the specified registration number. See annex for further information.

2020-12-21


Dipl.-Wi.-Ing. (FH) Sören Scholz
Head of Certification Body



ANNEX

Page 1 of 1

Certificate	10F001 dated 2020-12-21
Technical Data	Measuring device: float system Transfer of measured values: values: mechanically by float rod with bellow Operating pressure: 6 bar, 10 bar and 16 bar (according to design) Ambient temperature: -10 °C to +70 °C Medium temperature: 350 °C and +400 °C (according to design) Rated voltage: 250 V AC, 5 A and DC 30 V, 0,4 A Installation position: horizontal
Testing laboratory/ Inspection body	TÜV Rheinland Industrie Service GmbH Am Grauen Stein 51105 Köln GERMANY
Test report(s)	FBW 1810/15 dated 2015-10-07 968/FI 1018.00/18 dated 2018-09-24 968/FI 1018.01/19 dated 2019-09-27968/FSP 2160.00/20 von 2020-11-25