



Product Service

# CERTIFICATE

No. Z10 027632 0002 Rev. 01

**Holder of Certificate:** FISCHER  
**Mess- und Regeltechnik GmbH**  
Bielefelder Straße 37a  
32107 Bad Salzuflen  
GERMANY

**Factory(ies):** 027632

**Certification Mark:**



**Product:** Level indicator  
Level Limiter

**Model(s):** NK10

**Parameters:** 1oo1 configuration: SIL 1/2  
1oo2 configuration: SIL 3

Degree of protection: IP55  
Rated output current  
at 250Vac: 6A  
at 250Vdc: 250mA

**Tested according to:** IEC 61508-1:2010  
IEC 61508-2:2010

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

**Test report no.:** 717503460

**Valid until:** 2025-10-25

**Date,** 2020-10-26

  
( Claudio Gregorio )

ZERTIFIKAT ◆ CERTIFICATE ◆ 認證書 ◆ CERTIFICADO ◆ CERTIFICAT